

RAJSHREE SUGARS & CHEMICALS LIMITED

Factory: Unit II, Mundiyampakkam Post, Villupuram District, Pin - 605 601
Tel: (04146) - 232228 / 232401 / 232402 Fax: (04146) - 232403. E-mail: mpakkam@rajshreesugars.com

We had acquired the High Pressure Boiler from M/s. Thyssen Krupp Industries India Pvt. Limited – Pune for our Cogeneration Project installed at Mundiyampakkam, Villupuram District, Tamilnadu.

The Boiler Rating: Multi Fuel Boiler. Working Pressure; 87 ATA 515°C (+or- 5°C)
Generating Capacity; 120 TPH

We had commissioned the Boiler during the year 2005. We have loaded the boiler almost to the full capacity and generating power 22.5 MW by SKODA TG Set with 100% PLT

We had conducted the Performance Guarantee Test for the Boiler on Tuesday the 14th February 2006. All the parameters were recorded during the operation. The parameter figures concerned with all operation are within the limits. We are satisfied with the operation of Boiler continuously at full load.

We are very much satisfied with the performance of the Boiler

15.02.0225. Mundiyampakkam R P Venugopal Chief Project Executive.

Regd. Office: "The Uffizi" 338, Avinashi Road, Peelamedu, Coimbatore - 641 004 - Tamilnadu - India Tel # 91 - 422 - 2580981 - 83, Fax # 91 - 422 - 2577929

E-mail:rscl@rajshreesugars.com url:www.rajshreesugars.com